Coach8 Information Sheet

Number 3
March 2026

10 / 27 South Pine Road, Brendale QLD 4500
P: 1300 253 464 E: educate@coach8.com.au

Dehumidification in Building Moisture Control and Restoration: Psychrometric Principles, Vapour Pressure Control, and HVAC Interaction

Abstract

Effective moisture control in contemporary buildings requires an understanding of dehumidification as a psychrometric and vapour-pressure-driven process rather than a temperature-based intervention alone. This paper examines dehumidification fundamentals, system technologies, performance metrics, and interactions with HVAC systems and building assemblies using established building science principles. Particular emphasis is placed on dew point temperature control, latent moisture removal, and the influence of ambient vapour pressure on the equilibrium moisture content of hygroscopic materials within the context of building operation and professional water damage restoration.

Introduction

Modern buildings exhibit increasingly complex moisture behaviour due to tighter building envelopes, elevated internal moisture loads, and the widespread use of integrated mechanical systems. Dehumidification plays a critical role in maintaining indoor environmental conditions, influencing material moisture content, and mitigating moisture-related deterioration. In restoration contexts, dehumidification is applied to reduce ambient vapour pressure and thereby promote moisture migration from wetted materials toward equilibrium. This paper presents a technically conservative examination of dehumidification grounded in psychrometric principles and established HVAC and building science concepts.

Internal Moisture Loads, Ventilation, and Occupant-Generated Vapour

In occupied buildings, internal moisture generation represents a continuous vapour source that materially influences indoor humidity, vapour pressure, and condensation risk. Routine domestic activities, including respiration, cooking, bathing, laundering, and general occupancy, contribute several kilograms of water vapour per day to a typical family residence, forming a persistent internal moisture load.

Moisture generation from occupant respiration provides a sustained baseline vapour input, while intermittent activities such as showering and clothes drying introduce transient vapour releases. In buildings with high envelope airtightness, reduced uncontrolled air leakage limits passive dilution of this internally generated moisture. Where ventilation rates are insufficient relative to moisture generation, absolute humidity increases, elevating indoor vapour pressure and increasing the likelihood of condensation at cooler surfaces.

This risk is particularly pronounced during HVAC cooling seasons. Mechanical cooling reduces air temperature and sensible load but does not necessarily reduce vapour pressure unless latent control is explicitly provided. As cooled air contacts colder building elements such as glazing, supply air diffusers, or thermally bridged components, surface temperatures may fall below the indoor air dew point temperature, resulting in condensation even when relative humidity appears moderate.

Ventilation plays a primary role in managing internal moisture loads by removing water vapour before it can condense or be absorbed into hygroscopic materials. Temperature control alone does not reduce vapour pressure, and increased cooling capacity without corresponding latent control may increase condensation risk.

Australian Climate Zones and Their Influence on Moisture Control

Australia encompasses a wide range of climate zones, each presenting distinct moisture control challenges that influence dehumidification requirements, HVAC operation, and condensation risk. Broadly, these include hot–humid tropical regions, warm–humid subtropical regions, hot–dry arid and semi-arid regions, and cool temperate zones. As a result, external moisture loads and seasonal vapour pressure conditions vary across regions, shifting the balance between latent and sensible conditioning demands.

These climate characteristics align with the climate zone framework adopted within the National Construction Code, which recognises that regional climate conditions materially influence condensation risk, moisture management strategies, and overall building performance.

In tropical and northern coastal regions, persistently high ambient humidity and elevated dew point temperatures result in a dominant latent moisture load throughout much of the year. In these environments, mechanical cooling alone is often insufficient to control vapour pressure, and dedicated dehumidification is commonly required during normal operation as well as post-inundation drying.

Subtropical regions experience pronounced seasonal variability, with elevated humidity during cooling seasons and lower vapour pressure during cooler periods. Moisture-

related distress in these climates often manifests during summer when warm, moisture-laden outdoor air is introduced into conditioned spaces.

Arid and semi-arid regions typically experience low external humidity, with indoor vapour pressure driven primarily by internal moisture generation. While condensation risk is reduced under steady conditions, intermittent moisture generation or abrupt changes in ventilation can still produce localised condensation events.

Cool temperate regions are characterised by lower ambient temperatures and seasonal heating demand. Condensation risk in these climates is commonly associated with cold surface temperatures rather than high absolute humidity, with vapour pressure driven primarily by internal moisture loads during heating seasons.

Fundamentals of Dehumidification and Moisture Migration

Dehumidification refers to the removal of water vapour from air and is distinct from the drying of materials, which occurs as a consequence of vapour pressure imbalance. Moisture migration from materials occurs when the vapour pressure at or near the material surface exceeds that of the surrounding air. Lowering ambient vapour pressure through dehumidification increases this differential, promoting evaporation and diffusion as the material moves toward equilibrium moisture content. Temperature influences the rate and capacity of this process by affecting the saturation vapour pressure of the air at the material surface and, consequently, the vapour pressure gradient between the material and the surrounding air.

Psychrometric Basis of Dehumidification

Psychrometric relationships govern all air-based dehumidification processes, regardless of the moisture removal mechanism employed. Humidity ratio represents the absolute moisture content of air, while vapour pressure and dew point temperature describe the thermodynamic state at which moisture removal may occur.

In condensation-based dehumidification, moisture is removed by cooling air below its dew point temperature, resulting in latent heat removal as water vapour changes phase. In desiccant-based dehumidification, moisture is removed by exposing air to a surface with a lower water vapour pressure, driving vapour migration from the air to the desiccant without requiring cooling below the dew point temperature.

In both cases, effective dehumidification is characterised by a reduction in humidity ratio. Psychrometric analysis therefore demonstrates that changes in relative humidity alone do not reliably indicate moisture removal unless accompanied by a measurable decrease in humidity ratio.

Dehumidifier Technologies

Refrigerant Dehumidifiers

Refrigerant-based dehumidifiers remove moisture by cooling air below its dew point temperature across an evaporator coil, condensing water vapour, and discharging air at a reduced humidity ratio. In common dehumidification–reheat configurations, the condenser coil is positioned downstream of the evaporator coil, reheating the dehumidified air using heat rejected from the refrigeration cycle.

Performance is strongly dependent on entering air conditions, including dry-bulb temperature and humidity ratio, as well as achievable evaporator coil temperature. At low operating temperatures, evaporator surfaces may fall below freezing, resulting in frost accumulation and reduced dehumidification effectiveness until defrost control restores normal operation.

Desiccant Dehumidifiers

Desiccant dehumidification systems remove moisture by presenting a low vapour pressure surface to the air stream, driving vapour migration from the air to the desiccant. Solid desiccants operate primarily by adsorption, while liquid desiccants operate by absorption. Unlike cooling-based systems, desiccants do not require air to be cooled below its dew point temperature, enabling effective operation at lower dew point temperatures and air temperatures.

Thermal energy is required to regenerate the desiccant material, releasing captured moisture into a separate regeneration air stream. As a result of the heat of sorption, process air typically exits desiccant systems at a higher dry-bulb temperature than it entered.



Hybrid and Integrated Systems

Hybrid and integrated systems combine dehumidification with HVAC air distribution, enabling partial decoupling of latent and sensible control. These systems must be evaluated as complete hygrothermal assemblies, as refrigerant-based systems introduce sensible reheat while desiccant systems impose both a process-air temperature rise and a regeneration energy requirement. System selection and control therefore require a whole-system assessment of latent capacity, sensible impacts, and the ability to maintain stable indoor dew point temperature under anticipated operating conditions. In variable-capacity HVAC systems, effective latent moisture control remains sensitive to load matching, airflow, and sensible heat factor. Oversizing, even in inverter-based equipment, can shift system operation toward higher sensible fractions and reduced run-time in latent control regimes, diminishing dehumidification effectiveness despite apparent capacity.

Performance Metrics and Measurement Methods

Dehumidifier performance is typically expressed as moisture removal rate under specified test conditions, airflow rate, and power input. In many product specifications, these values are reported under standardised laboratory conditions commonly referred to as AHAM ratings, which are based on fixed laboratory conditions and therefore provide a comparative reference rather than a direct predictor of field performance. Field performance is therefore dependent on entering air conditions, airflow distribution, internal moisture loads, and control strategy.

Interaction with HVAC Systems and Building Assemblies

Dehumidification alters the balance between latent and sensible loads experienced by HVAC systems. Cooling-based dehumidification increases sensible heat through reheat, while desiccant systems introduce sensible heat through sorption. Within building assemblies, reductions in ambient vapour pressure promote moisture diffusion and desorption from hygroscopic materials, provided surface temperatures remain above the dew point temperature of the adjacent air.

Practical Implications for Moisture Control and Restoration

In professional water damage restoration, dehumidification systems should be selected and controlled based on achievable vapour pressure reduction and dew point temperature depression rather than relative humidity targets alone. AS–IICRC S500 – Standard for Professional Water Damage Restoration emphasises achieving drying objectives without introducing secondary damage, requiring psychrometric-based information to support the correct selection and implementation of appropriate drying equipment.

Internal moisture loads generated by occupants are a critical factor that can influence dehumidification effectiveness and extend drying timelines. In occupied structures, continuous vapour generation may offset moisture removal, requiring greater latent removal capacity to achieve and maintain the vapour pressure differentials necessary for drying. When refrigerant dehumidifiers are used, this is typically addressed through increased unit quantity, operation at favourable entering air conditions, extended run time, or a combination of these measures. In HVAC-integrated systems, similar outcomes may be achieved through airflow adjustment, control of sensible heat factor, or the addition of dedicated latent capacity, such as standalone dehumidifiers or desiccant-based systems operating independently of sensible cooling demand.

Limitations and Boundary Conditions

This analysis is based on established building science principles and recognised dehumidification mechanisms. Actual performance outcomes remain dependent on site-specific conditions, climate zone, internal moisture loads, airflow distribution, system configuration, and control methodologies.

Conclusion

Dehumidification is governed by psychrometric relationships, vapour pressure differentials, and latent heat transfer. Effective application in building operation and water damage restoration requires an understanding of climate context, internal moisture loads, system limitations, and HVAC interaction. When applied within these constraints, dehumidification remains a critical component of moisture management in Australian buildings.

References

Australian Building Codes Board (ABCB). National Construction Code (NCC). Canberra, ACT.

AS–IICRC S500 – Standard for Professional Water Damage Restoration.

ASHRAE Handbook of Fundamentals. American Society of Heating, Refrigerating and Air-Conditioning Engineers.

Condensation in Buildings Handbook. Building science reference text.

Munters. Dehumidification Handbook and engineering literature.